



भारतीय प्रौद्योगिकी संस्थान कानपुर
INDIAN INSTITUTE OF TECHNOLOGY KANPUR
संगणक केन्द्र
COMPUTER CENTRE

पत्रालय-आई.आई.टी.कानपुर-208016(भारत)
P.O.-I.I.T. KANPUR - 208 016 (India)

CC/IITK/09/197
July 12, 2016

Notice Inviting Tender for supply of 12V, 42 & 65 AH SMF (VRLA)
Battery

We invite Technical & Financial bids from reputed manufacturers and authorised dealers for the supply of SMF batteries for our existing UPS systems installed at different locations in IITK. The distributor/dealer must enclose a certificate that they are the authorised distributor of the OEM (original equipment manufacturer).

You are requested to submit detailed *technical* & financial bid in separate sealed envelopes addressed to **Head, Computer Centre, IIT Kanpur-208016.**

Last date for submission of technical & financial bid is **29.07.2016** at 1700 hrs. in Office, Computer Centre, IIT Kanpur 208016.

Specification

Parameter		Requirement
Quantity		60
Type		SMF (VRLA)
Normal Voltage		12V
Maximum Dimensions (mm)	Length	200
	Width	165
	Height	170
Minimum Weight		14 Kg
Terminal		Lead Post
Capacity at 25°C at 20 hour discharge rate		42AH
Confirming Standard		JIS C 8702
Test Report		CPRI/ETDC (attach test report copy)
Complying Certificate		ISO 9001, ISO 14001, OHSAS 18001
Warranty		Two Years On Site replacement warranty

Cont. page -2


[Handwritten Signature]
12/07/2016.

Specification

Parameter		Requirement
Quantity		70
Type		SMF (VRLA)
Normal Voltage		12V
Maximum Dimensions (mm)	Length	350
	Width	166
	Height	174
Minimum Weight		20 Kg
Terminal		Lead Post
Capacity at 25 °C at 20 hour discharge rate		65AH
Confirming Standard		JIS C 8702
Test Report		CPRI/ETDC (attach test report copy)
Complying Certificate		ISO 9001, ISO 14001, OHSAS 18001
Warranty		Two Years On Site replacement warranty

Terms & Conditions:

- Sales tax, services tax or any other type of tax (excluding Custom/Excise) should clearly be mentioned, and the quoted price shall be inclusive of all the Taxes (excluding Custom/Excise).
- Validity of the quotation should be 3 months.
- The original brochures of the quoted items should be attached.
- Price may be quoted without Customs/Excise Duty. Exemption Certificate will be provided by IITK.
- The Head, CC IITK also reserves the right to accept or reject any or all the tenders either in full or in parts without assigning any reason.
- The envelopes must be superscribed with "Technical Bid for the supply of batteries in response to enquiry no. ---- or Financial Bid for the supply of batteries in response to enquiry no. ---- as the case may be for the supply of Batteries".
- The bidder should have an authorised agent who should replace battery in case of fault within 48 hours.


(Dr. Y.N. Singh) 12/07/2016.
Head *Prasanna*