

1/2



भारतीय प्रौद्योगिकी संस्थान कानपुर
INDIAN INSTITUTE OF TECHNOLOGY KANPUR
संगणक केन्द्र
COMPUTER CENTRE

Prof Y.N. Singh
Head

पत्रालय - आई.आई.टी.कानपुर - 208 016 (भारत)
P.O.-I.I.T. KANPUR - 208 016 (India)

04 July 2016

CC/IITK/09/188

ADDENDUM


Reference: Tender No. CC/IITK/09/176 dated 16 June 2016

S.No.	Page	Content as per original tender enquiry	Modifications/Additions
1	3	Point b of section 7i) The authorized business partner must also be either a manufacturer of high capacity three-phase UPS's for data centers with load of at least 600KVA or an authorized distributor and service provider of the same.	To be read as: The authorized business partner must also be either a manufacturer or an authorized distributor / service provider of high capacity three-phase UPSs for data centers with load of at least 300KVA.
2	4	Point ix) Annual turnover of the bidder during the last three years should not be less than Rs.50 Crores.	To be read as: Annual turnover of the Battery OEM during the last three years should not be less than Rs.50 Crores. The annual turnover of business partner authorized by OEM, if the OEM is not directly participating, should not be less than Rs. 3 Crores during the last three years.
3	4	During warranty period any defective battery should be replaced by new battery of the same make and model.	To be read as: During warranty period any defective battery should be replaced by new battery of the same make and model within 2 working days.

M. Singh
04/07/2016

4	5	No. of cycles at 30% DOD – 1800 or more	To be read as: No. of cycles at 30% DOD – 1400 or more
---	---	---	---

The last date and time of submission is hereby extended to 1700 hrs on July15, 2016. Other terms and conditions remain the same


(Dr. Y.N. Singh) 04/07/2016