


QUOTATION

Name of work :- Replacement of defective MCCB, MCB, distribution board with allied electrical work at house no-3013 to 3018 IIT Kanpur.

S.No.	Description of item	Qty.	Unit	Rate	Amount
(In words & Figures)					
1	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.				
1.1	6 x 6 sq. mm	30.00	Metre		
2	Providing and fixing following sizes of PVC casing and capping on surface as reqd.				
2.1	32 X 16 mm	10.00	Mtr.		
3	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)				
3.1	12 way , Double door	1.00	Each		
4	Supplying and fixing of following ways surface/ recess mounting, vertical type, 415 volts, TPN MCB distribution board of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, din bar for mounting MCB's (but without MCB's and incomer) as required . (Note : Vertical type MCB TPDB is normally used where 3 phase outlets are required.) and should have provision for MCCB as incomer.				
4.1	4 way (4 + 12), Double door	1.00	Each		
5	Supplying and fixing 40 amps to 63 amps rating, 240/415 volts, "C" curve, Double pole miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.	6.00	Each		

S.No.	Description of item	Qty.	Unit	Rate (In words & Figures)	Amount
6	Supplying and fixing 100 amps rating, 415 volts, "C" curve, Triple pole miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.	4.00	Each		
7	Providing and fixing following rating and breaking capacity and pole MCCB with thermomagnetic release and terminal spreaders in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required.				
7.1	200 A,36KA,FPMCCB	1.00	Each		
8	Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.				
8.1	3½ X 25 sq. mm (28mm)	4.00	Each		
8.2	3½ X 50 sq. mm (35mm)	2.00	Each		
Grand Total					


 राघवेंद्र सिंह 11/12/20
RAGHVENDRA SINGH
 अध्यापक अभियंता (वि०) E.E. (Elect.)
 संनिविदा, भा० प्र० सरस्वती, कानपुर
 I.W.D., I.I.T., Kanpur
