

## QUOTATION

Name work : Providing additional street light in the lawn of H.No. 3004 as per enclosed complaints.

SN	Description	Qty	Unit	Rate	Amount
				(In words & Figures)	
1	Numbering of ceiling fan/ exhaust fan/ fluorescent fittings as required	1.00	Nos.		
2	Providing and fixing 6 SWG dia. GI wire on surface or in recess for loop earthing as required.	55.00	Mtr.		
3	Supplying and making indoor end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed/XLPE aluminium conductor cable of 1.1kV grade/as reqd.				
a	2x6 sqmm(19mm)	2.00	Set		
4	Providing, laying and fixing following dia G.I. pipe (medium class) in ground complete with G.I. fittings including trenching (75 cm deep) and re-filling etc as required				
a	40mm dia	3.00	Mtr.		
5	Supplying & Laying of one no. XLPE cable aluminium conductor steel armoured cable of size 2x6sqmm, grade 1.1kV in following manners.				
a	In Ground I/c excavation, sand cushioning protective covering, refilling of earth as reqd.	48.00	Mtr.		
b	In existing pipe	3.00	Mtr.		

SN	Description	Qty	Unit	Rate	Amount
----	-------------	-----	------	------	--------

(In words & Figures)

c In existing open duct 4.00 Mtr.

6 Supply & fixing of 65 mm dia.'B' class GI pole 4.5 mtr. Long for post top lantern i/c base plate 300 x 300 x 3mm GI reducer & nipple for mounting the fitting with painting etc. grouting in cement concrete 1: 3: 6 (1 cement : 3 coarse sand : 6 grade stone aggregate 40mm nominal size 0.4mm dia x 0.5 mm high to accomade the looping) complete as reqd.

7 Supplying and drawing of following sizes of FR PVC insulated copper conductor, 3 core round cable of following size in the existing surface/ recessed steel/ PVC conduit as required.

a 1.5 Sq.mm 5.00 Mtrs.

8 Supplying,fixing,testing commissioning of garden light 40W LED postop lantern Luminures. New generation, post-top, energy saving, environmental friendly, long life aesthetically designed with symmetrical light distribution, spun aluminium landscape luminaire with high power LEDs as light source make:Crompton Greaves Havells or its equivalent on the existing pole complete as required.

SN	Description	Qty	Unit	Rate	Amount
----	-------------	-----	------	------	--------

(In words & Figures)

9	S&F, connecting and commissioning looping type cable end control box with 2mm fabricated CRCA sheet of size 200 mm x 200 mm x 125 mm having 1 no. 6amp to 32 amp SPMCB 250 volt and 2 nos. brass neutral link square rod 6 way and fixed on 5 mm thick bakelite sheet. Box shall have almirah type hing and panel key type lock front door duly painted with earthing strud etc. complete as required.	1.00	Nos.		
---	--	------	------	--	--

Total Rs.

\_\_\_\_\_

\_\_\_\_\_

अविश्वसनीय अडिवायन (डिवा) E.E. (Elect.)  
 स.प.डि.सि.स.भा.डी.स.संस्थान, वानगुडा  
 B.K.D., I.T., Karpur

*(Signature)*