

QUOTATION


Subject Repairing/replacement of defective light fittings in toilet, stair and joining corridor in L-18, L-19 and 20.

S.No.	DESCRIPTION	Qty	UNIT	RATE	AMOUNT
-------	-------------	-----	------	------	--------

(In words & Figures)

- | | | | | | |
|---|---|-------|------|--|--|
| 1 | Supply and fixing of following LED light fixture with efficiency >100 lumen/ watt, P.F. >0.95, THD<10%, Electronic driver, LED lamp, reflector, diffuser, MS body/housing holder etc. complete with all fixing accessories and lamp as required complete. | | | | |
| a | 18 watt surface mounting 300 x 300 mm LED light fixture | 44.00 | Nos. | | |
| 2 | Dismantling, disconnecting old damaged unserviceable fl fitting/ exhaust fan/ ceiling fan/ bulkhead fitting with bracket etc. as reqd. and depositing in sectional store. | 40.00 | Nos. | | |

Total Rs.


प्रमाणित प्रबंधक (सि)/E.E (Elect.)
पता: माता प्रीत सभाग, कानपुर
C.W.D., I.I.T. Kanpur
