

INDIAN INSTITUTE OF TECHNOLOGY KANPUR
INSTITUTE WORKS DEPARTMENT
ELECTRICAL & AIR-CONDITIONING DIVISION

No. 08/AC/EE/2022/ 21

Dated 18-04-2022

QUOTATION NOTICE

M/s

Sealed quotations are invited from the eligible Electrical contractor by the undersigned on behalf of the Director, IIT Kanpur for "**Providing power supply for UPS with associated work installed in sound (Room no:-107) at New SAC Building..**" As per enclosed Bill of Quantity/overleaf, so as to reach in this office on or before 27-04-2022 upto 3.00 PM and the quotation will be opened on the same day at 3.30PM in the presence of quotationers or their representative who want to be present.

The terms and conditions of the quotation are as under:

1. The quotations should be submitted
2. in a properly sealed envelop, addressed to the undersigned. The enquiry nos. and date should invariably quoted on the top of the envelop.
3. The time allowed for carrying out the above noted work is 14(Fourteen) Days.
4. The rates quoted should be exclusive of GST, no other tax is payable except GST. GST shall be applicable as per Govt. norms..
5. Security @ 6% shall be deducted from the bills which shall be released on successful completion of defect liability period of six months.(NA)
6. The estimated cost of quotation is **Rs.23649/-**. The required earnest money of **Rs. NIL/-** is to be submitted in the form of FDR pledged in favour of the Director, IIT Kanpur alongwith the quotation. The earnest money of the unsuccessful quotationers will be returned within one month's time.
7. The quotations shall remain valid for 90 days from the date of opening.
8. Income tax will be recovered as per notification of Government from the bill and the amount so recovered will be deposited in the State Bank of India at the credit of the firm.
9. The earnest money/Security deposit will be regulated as per the norms of C.P.W.D.
10. The Institute reserves the right of accepting or rejecting any quotations without assigning any reason thereof.
11. The material should be used as per approved list of make.

QUOTATION

Sub: Providing power supply for UPS with associated work installed in sound (Room no:-107) at New SAC Building.

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
1	Supplying and drawing following sizes of FR PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit/ PVC trunking as required.				
a)	6 x 10 sq. mm	10.00	Mtr.		
2	Fixing of PVC/MS box of any size on surface/recessed including rag bolts etc. Complete as required.	2.00	Nos.		
3	Providing and fixing on surface with screw of size 32 mm x 12.5 mm. DLP mini trunking system with independent cover as reqd.	2.00	Mtrs.		
4	Providing and fixing accessories for following size of DLP mini trunking system as reqd. (32 mm x 12.5 mm)				
a)	Flat Junction	2.00	Nos.		
b)	Changeable flat angle	2.00	Nos		
c)	Changeable internal/External angle	2.00	Nos.		
d)	End cap left or right	1.00	Nos.		
5	Providing & fixing of following size of DLP trunking on surface with suitable plug & screws as reqd. (105 mm x 50 mm)	10.00	Mtrs.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
6	Providing & fixing of accessories for following size of DLP trunking system as reqd. (105 mm x 50 mm.)				
a)	Flexible cover for 85 mm width	10.00	Mtr		
b)	End Caps	5.00	Nos.		
c)	Base Joint	3.00	Nos.		
d)	Joint for 85 mm width cover	3.00	Nos.		
e)	Flat junction	3.00	Nos.		
f)	Flat angle	4.00	Nos.		
g)	Internal angle adjustable from 80 - 100	2.00	Nos.		
h)	External angle adjustable from 60 - 120	2.00	Nos.		
7	Drawing of RG-6 cable /network cable/wiring cable/telephone cable in existing surface / concealed conduits reqd.	60.00	Mtrs.		
8	Supplying and fixing 3 mm thick phenolic laminated sheet on existing board with brass screw and cup washer etc. complete as required.	100.00	Sq. Inch		
9	Locating and rectifying fault in wiring , restoring supply & making good the damages etc. complete as reqd.	1.00	Nos.		

S.N.	Description	Qty.	Unit	Rate (Rs.) Words & Fig.	Amount
10	Supply, fixing, testing and commissioning LED tube including connection complete as required.				
a)	LED GLASS Tube 20w, T8 ,single/double sided inbuilt driver, (Make_Crompton_LGT8-20-865-2 or equivalent)	4.00	Nos.		
11	Supply, Installation, testing & commissioning of AC ceiling fan of following sweeps, alluminium die cast body , copper wound, double bearing, less 70 watts 220 volts 50 Hz without regulator l/c wiring the down rods of standard length up to 30 cm with 1.5 sq.mm. PVC insulated copper conductor single core cable etc as reqd. (ISI marked.)				
a)	1200 mm Make_Bajaj Kassels/or approved Make.	1.00	Nos.		

Total Rs.

अविश्वी अभियंता (काठ) E.E. (A.C.)
संनिविदा, माओसंस्थान, कानपुर
I.W.D., LLT Kanpur