## **Indian Institute of Technology Kanpur**

Dr. Ashis K. Patra, Ph.D. Assistant Professor



Department of Chemistry Core Laboratory, Room No. 201E IIT Kanpur, Kanpur 208016, India Tel: +91-512-259-6780

FAX: +91-512-259-7436 E-mail: akpatra@iitk.ac.in

Date: August 26, 2013

**Enquiry No: CHM/AKP/2013-14/03** 

**Closing Date: September 08, 2013** 

**Subject: Request for quotation for online UPS** 

Dear Sir/Madam:

Sealed quotations are invited very urgently for purchase of online UPS of 6 kVA with

## Batteries for back up of 1 hour and a battery stand with following specifications or better:

- 1. The UPS must be of a renowed make with a rating of 6 kVA with batteries for back up for 1 hour alongwith a battery stand.
- 2. Some features include: double conversion online topology, high frequency technology, fully microprocessor-controlled design, wide input voltage range, near unity input power factor, automatic bypass, smart self diagonosis function, full time lightning and surge protection, UPS monitoring software.
- 3. Some protection feature are: Input over voltage/ under voltage, input over current, battery over charging, battery low output, over voltage and short circuit.
- 4. The system should set an alarm and/indicator on various functions like mains fail, input over voltage, inverter on, battery low, output under voltage, output over load etc.
- 5. Deatiled technical specifications of the UPS and accessories must be given. The price must include detailed price breakup for UPS and batteries, taxes and and AMC charges if any.

## **Terms & Conditions:**

- 1. Prices should be in INR, inclusive all taxes and CIF to IIT Kanpur, include the installation.
- 2. Warranty should be atleast two years for UPS and batteries.
- 3. Validity of quotations should be at least for 15 days. Delivery within 3 weeks.
- 4. Our organization is an educational institute and liable to get maximum educational discount from manufacturer. IITK is exempted from excise/custom duty.

Sealed envelope carrying best offer quotation and printed literature with technical specification should reach undersign by  $8^{th}$  September 2013, 5:00 PM to the following address preferably by speed post/courier.

Dr. Ashis K. Patra,
Department of Chemistry,
Core Lab. 201E,
IIT Kanpur, Kanpur-208016, U.P., INDIA
E-mail: akpatra@iitk.ac.in