

**Quotation Enquiry for battery back-up for Uninterrupted Power
Supply(UPS) for the Department of Chemistry, IIT Kanpur**

24 October, 2011

Formal quotations are invited for batteries for a 30 KVA online UPS for the Department of Chemistry, IIT Kanpur under buy-back scheme. Detailed specifications are given below.

1. Battery VAH rating: 36000 VAH (45 minutes back-up at full capacity)
2. The brand of the batteries should be either Panasonic or Exide. Batteries should be maintenance free (SMF) and should fit in the existing rack. If that is not the case, then quotation should be provided for the rack also.
3. All details should be specified for the battery (brand, quantity and A-H rating).
4. Buy-back of old batteries (30 nos of 3 year old 12V-100 AH SMF Batteries)
5. Warranty period : 2 years

The quotation should be sent in a single sealed envelope to Dr. Madhav Ranganathan, Department of Chemistry, IIT Kanpur 208016. Last date for receipt of the quotations is November 30, 2011.

Madhav Ranganathan

Department of Chemistry

IIT Kanpur

Kanpur 208016. India

Tel: 0512-2596037

Fax: 0512-2597436

Email: madhavr@iitk.ac.in