Indian Institute of Technology Kanpur Physical Education Section

November 24th 2015

Quotations are invited in single bid format for supply and installation of two priming tanks at Institute swimming pool.

Enquiry No: IITK/SWP/IISM/ 01

Opening Date : November 24, 2015

Closing Date : December 07, 2015

Description & specifications of Items:

1. Body Material : MS fabricated

2. Height : 1000mm
3. Diameter : 750mm
4. Thickness of sheet : 08 mm
5. Air Release Valve : 01 No.

6. Lid Flange Thickness : 18mm

- 7. Gasket Lining on Lid for Leakage Protection
- 8. Nut & Bolt Locking System
- 9. Strainer Net Basket (Suitable size body Material with Brass Net, Height -600mm, and Diameter: 450mm)

The prices must include dismantling of existing old priming tanks, installation of new tanks with all accessories & Water supply connections to related pumps.

Terms and Conditions:

- Quotation should be submitted in the properly sealed envelope along with a copy of tender.
- •The enquiry no. and date should invariably be quoted at the top of the envelope.
- •.Firm's expertise in swimming pool filter plant operations and maintenance will be preferred.
- Validity of quotation should be at least for 90 days.

- · Warranty/Guarantee should be clearly mentioned.
- Prices should be on FOR IIT Kanpur & should include the dismantling and installation charges as per the requirement.
- The indenter reserves the right to withhold placement of final order.
 The right to reject all or any of the quotations and to split up the requirements or relax any or all of the above conditions without assigning any reason

Send your quotation in a sealed envelope vide **Enquiry No: IITK/SWP/IISM/ 01** at the top of the envelope at the following address on or before 4:00 PM of 07th December, 2015

Thanking You,

(Nihar Ranjan Patra)

Chairman SPEC

N.h a Paton

Physical Education Section

Institute Sports stadium

IIT Kanpur

Kanpur- 208016 (UP)